

# **Annual CCR Fugitive Dust Control Report**

## **for**

# **Coffeen Power Plant**

*Prepared for:*



**Illinois Power Generating Company**

**Coffeen Power Plant  
134 Cips Lane  
Coffeen, IL 62017**

November 2018



**Coffeen Power Plant  
ANNUAL CCR FUGITIVE DUST CONTROL REPORT**

CCR Activity	Actions Taken to Control CCR Fugitive Dust
Handling of CCR at the facility	CCR fly ash to be emplaced in the landfill is conditioned before emplacement.
	Load CCR transport trucks from the CCR fly ash silo using a chute with a sock (skirt).
	Perform housekeeping, as necessary, in the fly ash loading area.
	Operate fly ash handling system in accordance with good operating and good air pollution control practices.
	Maintain and repair as necessary dust controls on the fly ash handling system.
Transportation of CCR at the facility	CCR to be emplaced in the landfill is conditioned before emplacement.
	Cover or enclose trucks used to transport CCR fly ash.
	Limit the speed of vehicles to no more than 15 mph on facility roads.
	Cover or enclose trucks used to transport CCR other than fly ash, as necessary.
	Sweep or rinse off the outside of the trucks transporting CCR, as necessary.
	Remove CCR, as necessary, deposited on facility road surfaces during transport.
	Water CCR haul roads, including landfill roads, as necessary.

Based on a review of the Plan and inspections associated with CCR fugitive dust control performed in the reporting year, the control measures identified in the Plan as implemented at the facility effectively minimized CCR from becoming airborne at the facility. No revisions or additions to control measures identified in the Plan were needed.

No material changes occurred in the reporting year in site conditions potentially resulting in CCR fugitive dust becoming airborne at the facility that warrant an amendment of the Plan.

## **Section 2 Record of Citizen Complaints**

No citizen complaints were received regarding CCR fugitive dust at Coffeen Power Plant in the reporting year.