

August 14, 2019

In accordance with Title 40 Code of Federal Regulations (C.F.R.) § 257.95(g), the owner or operator of a coal combustion residuals (CCR) unit must prepare a notification that identifies constituents listed in Appendix IV of 40 C.F.R. Part 257 that have exceeded groundwater protection standards established under 40 C.F.R. § 257.95(h). The notification must be placed in the facility's operating record within 30 days of detection (40 C.F.R. § 257.105(h)(8)).

The following Appendix IV constituent was detected at statistically significant levels above the applicable groundwater protection standard established pursuant to 40 C.F.R. § 257.95(h) during assessment monitoring at Miami Fort Basin A:

- Cobalt
- Molybdenum

Miami Fort